

March 26, 2011

Nuclear and Industrial Safety Agency

Regarding the result of concentration measurement in the stagnant water on the basement floor of the turbine building of Unit 1 of Fukushima Dai-ichi Nuclear Power Station

Regarding the issue above, as the result of concentration measurement of each radioactive nuclide was reported from Tokyo Electric Power Company, it is informed as attached.

(Contact Person)

Mr. Toshihiro Bannai

Director, International Affairs Office,
NISA/METI

Phone:+81-(0)3-3501-1087

(Tentative Translation)

March 25th, 2011
Tokyo Electric Power Co.
Fukushima Dai-ichi NPS

Regarding the result of concentration measurement in the stagnant water on the basement floor of the turbine building of Unit 1 of Fukushima Dai-ichi Nuclear Power Station

Radioactive Nuclide	Concentration (Bq/cm ³)
Cl-38	1.6×10^6
As-74	3.9×10^2
Y-91	5.2×10^4
I-131	2.1×10^5
Cs-134	1.6×10^5
Cs136	1.7×10^4
Cs-137	1.8×10^6
La-140	3.4×10^2