Fukushima Di-ichi Nuclear Power Station Major Parameters of the Plant (As of 14:00, March 27th)

Unit No.	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
	Injecting freshwater via the	Injecting freshwater via the Fire	Injecting freshwater via the Fire			Cint o
Situation of water injection	Water Supply Line.	Extinguish Line.	Extinguish Line.			
	Flow rate of injected water : 120	Flow rate of injected water :270	Flow rate of injected water: 220	Under	Under	Under
	Ø/min	\sim 280 ℓ /min	Ø/min	shutdown	shutdown	shutdown
	(As of 15:37, March 25th)	(As of 17:22, March 26th)	(As of 18:00, March 26th)			
	temporary measuring instrument	temporary measuring instrument	temporary measuring instrument			
					Shutdown	Shutdown
Reactor water level	E1		F1 A. 1 000		range	range
	Fuel range A: -1,650mm	Fuel range A: -1,200mm	Fuel range A:-1,900mm	#2	measurement	measurement
	Fuel range B: -1,600mm (As of 9:00, March 27th)	(As of 9:00, March 27th)	Fuel range B:-2,300mm	#2	1,930mm	2,035mm
	(As of 9:00, March 27th)		(As of 10:10, March 27th)		(As of 14:00,	(As of 14:00,
					March 27th)	March 27th)
Reactor pressure	0.374MPa g(A)	-0.018MPa g (A)	0.032MPa g (A)		0.007MPa g	0.005MPa g
	0.416MPa g(B)	-0.020MPa g (B)	-0.099MPa g (C)	#2	(As of 14:00,	(As of 14:00,
	(As of 9:00, March 27th)	(As of 9:00, March 27th)	(As of 10:10, March 27th)		March 27th)	March 27th)
Reactor water temperature				#2	30.3℃	29.1℃
	(Impossible collection due to low	system flow rate)			(As of 14:00,	(As of 14:00,
					March 27th)	March 27th)
	Feedwater nozzle temperature:	Feedwater nozzle temperature:	Feedwater nozzle temperature:	Unit 4		
Reactor Pressure Vessel	224.8°C	123.6℃	13.6℃ (under survey)	No heating element (fuel) inside the reactor Unit 5,6 Monitoring by the reactor water temperature		
(RPV) temperature	Temperature at the bottom head	Temperature at the bottom head	Temperature at the bottom head			
	of RPV: 143.4°C	of RPV: 111.2℃	of RPV: 121.6℃			
	(As of 9:00, March 27th)	(As of 9:00, March 27th)	(As of 10:10, March 27th)			
D/W*1 Pressure, S/C*2 Pressure	D/W: 0.270MPa abs	D/W: 0.110MPa abs	D/W: 0.1076MPa abs			
	S/C: 0.270MPa abs	S/C:Down scale (under survey)	S/C: 0.1806MPa abs	#2		
	(As of 9:00, March 27th)	(As of 9:00, March 27th)	(As of 10:10, March 27th)			
CAMS*3	D/W: 3.46×10^{1} Sv/h	D/W: 4.16×10^{1} Sv/h	D/W: 3.37×10^{1} Sv/h			
	$S/C: 2.22 \times 10^{1} Sv/h$	$S/C: 1.41 \times 10^{0} Sv/h$	$S/C: 1.31 \times 10^{0} Sv/h$	#2		
	(As of 9:00, March 27th)	(As of 9:00, March 27th)	(As of 10:10, March 27th)			
D/W*1 design operating pressure	0.384MPa g(0.485MPa abs)	0.384MPa g(0.485MPa abs)	0.384MPa g(0.485MPa abs)	#2		
D/W*1 maximum operating pressure	0.427MPa g(0.528MPa abs)	0.427MPa g(0.528MPa abs)	0.427MPa g(0.528MPa abs)			
operating pressure					37.8℃	21.0℃
Spent Fuel Pool water	ш1	67°C	ш1	#1		
	#1	(As of 9:00, March 27th)	#1	#1	(As of 14:00,	(As of 14:00,
	4.500				March 27th)	March 27th)
FPC skimmer level	4,500mm	5.750 (1)		5,850mm		
	(As of 9:00, March 27th)	5,750mm(under prow)	#1	(As of 10:10,	#2	
		(As of 9:00, March 27th)		March 27th)		
D1	Description and market 1 and 1		Pagaining automal naviar averaly (P/C4D)		Receiving external power	
Power supply	Receiving external power supply (P/C*4 2C)		Receiving external power supply (P/C4D)		supply	

Other information	Unit3: Collecting the data of RPV temperature and continuing survey for transitional situation Unit2: Confirmed the indicated value of S/C Pressure but continuing to survey the transition of condition	Common pool: about 39°C (As of 8:00, March 27th)
-------------------	--	--

Pressure conversion

Gauge pressure (MPa g) = Absolute pressure (MPa abs) – Atmospheric pressure (Normal atmospheric pressure 0.1013MPa)

Absolute pressure (MPa abs) = Gauge pressure (MPa g) + Atmospheric pressure (Normal atmospheric pressure 0.1013MPa)

*1 D/W : Dry Well

*2 S/C : Suppression Chamber

*3 CAMS : Containment Atmospheric Monitoring System

*4 P/C : Power Center

#1 : Measuring instrument malfunction

#2 : Except from data collection